

Subject: Fire Alarm - December 30th - 555 am and Garbage Chute
Date: Thursday, December 30, 2021 at 3:18:28 PM Mountain Standard Time
From: Truman Homes
Priority: High

Good Afternoon Residents,

Fire Alarm

This morning at 555am there was a fire alarm triggered from a burst sprinkler head.

The head that burst was located in the garbage room of the 8505 building.

Thankfully no damage occurred and all water was contained within the room.

The cause was the man door to the garbage room was wedged open with a garbage bag. The unit heater within the garbage room was not able to compete with the frigid temperatures causing a sprinkler head to freeze and burst.

Technicians have been on site all day running checks and diagnostics to ensure that the building is in full working order.

Please ensure that doors and windows are fully closed during cold snaps. Please ensure that doors to the garbage rooms, lobbies and the parkade are fully closed behind you before you depart.

Garbage Chute

Unfortunately several residents are still not following the guidelines while using the garbage chute.

There were over 21 boxes in the chute of 8505 this morning causing it to jamb.

PLEASE DO NOT PLACE ANY oversized bags and cardboard (of any kind) into the garbage chute.

